



CERTIFICATE

Sunmeet Enterprise

A-3 ASHIRWAD SOC. NANDEWAR ROAD
BHARUCH-392001
Ph. No. 02642260829 , mo. 9824475701
email: gsdigwa7@gmail.com

SUPPLIERS/DEALERS OF:
FIRE EXTINGUISHERS & FIRE HYDRANT
SYSTEM.

TO WHOMSOEVER IT MAY CONCERN

To: **SWAMI VIVEKANAND ACADEMY**
Nr. WAJIFDAR NI WADI, DIVA ROAD
ANKLESHWAR

DATE: 20-01-2022

Subject: Installation Report of Fire Hydrant Line, with Fire Extinguishers.

Dear Sir,

This is in context to the above subject , survey for installation for fire safety product was conducted on dated **26-10-2021** at Institutional Building named : **SWAMI VIVEKANAND ACADEMY** , in the area **DIVA, ANKLESHWAR** below mentioned was observed at the site

Observation Report:

- 1) The existing site named : : **SWAMI VIVEKANAND ACADEMY.**
- 2) Existing Building is **G+2**

Based on above observation report and as per fire safety norms below products were installed at the given site by **SUNMEET ENTERPRISE, BHARUCH.**

Installation Report:

- 1) 15 nos. of fire extinguishers were installed .
 - 6kg ABC type of fire extinguishers.(09NOS)
 - 4.5kg Co2 type of fire extinguishers.(06NOS)
 - MCP & HOOTER SET(06NOS)
 - Fire Panel.(01NOS)
 - Hose Reel Drum(03NOS)
 - 5Hp Main Fire Pump(01NOS)
 - Pump Auto Panel(01NOS)
 - 2 Way Fire Brigade Inlet(01NOS)